

FORM - A

(Form of application under sub-section (1) Sub-section (2) of section 4 of the Madras Public Buildings (Licensing) Act. 1965(Madras Act. 13 of 1965) referred to in Rule 3 of the Madras Public Buildings (Licensing) Rules 1966)

From

The Correspondent,
"MICHAEL JOB MATRICULATION HIGHER SECONDARY SCHOOL"
S.F.No:692/1A2B1, 692/1A2B2, 692/1A2B3, 693/1, 693/3
Komba Thottam, Ravathur,
MGP Road, Irugur Village,
Sulur Taluk,
Coimbatore District - 641109

To

The Tahsildar,
Sulur, Coimbatore

Sir,

1. I Intend / to use the building / to continue to use the existing building not at present used as public building / which is situated in S.F.No:692/1A2B1, 692/1A2B2, 692/1A2B3, 693/1, 693/3, Komba Thottam, Ravathur, MGP Road, Irugur Village, Sulur Taluk, Coimbatore District and specified in the statement enclosed, as a public building for a period of Three years and months from the **15.06.2021 to 14.06.2024 [Three years]**

2. The year of construction and present approximate ease of construction and the purpose for which it is to be used or is being used as public building as also furnished in the statement accompany this application.

3. I enclose a chalan for Rs.

4. I also enclose a certificate of structural soundness in the prescribed form furnished by the District Collector's Panel Engineer **Dr. M.V.MOHANAKRISHNAN**, Ph.D, MRICS, [London] B.E, (Civil), B.Tech (Mech), M.E. Strut (Hons)., M.Sc(REV) (P&M), M.B.A., M.I.E., F.I.V. F.I.C.C., F.A.C.C.E., M.I.C.A., P.G.D in Q.S and Valn, P.G.D in Strut (Hons), C.Engg., P.Engg & L.L.B.

Coimbatore District Collector's Panel Engineer - Class-1A,Registration No.02 / 2016.

Date :

Enclosure :

1. Statement

2. Chalan for Rs. towards the application fee.

FALCON ASSOCIATES

HEAD OFFICE :

216, Durais complex 1st floor
Raja mill Road,
Opp to CT Lodge
Pollachi- 642001
Ph: 04259- 228257.

BRANCH OFFICE:

386/11,Kamala Krishna Towers,
2nd Floor, Kamarajar Road, Lakshmipuram,
Ramanuja Nagar Bus Stop,
Peelamedu, Coimbatore -641015
Phone No.0422-2573259,

Email:falconpoy2003@gmail.com Cell: 98431 – 28257, 99430 – 28257

STABILITY CERTIFICATE

Name of the Applicant : "MICHAEL JOB MATRICULATION HIGHER SECONDARY SCHOOL"

Address: : S.F.No:692/1A2B1, 692/1A2B2, 692/1A2B3, 693/1, 693/3
Komba Thottam, Ravathur,
MGP Road, Irugur Village,
Sulur Taluk,
Coimbatore District - 641109

Purpose : School Purpose

Dr.M.V.Mohanakrishnan.Ph.D.,MRICS (UK),

B.E. (Civil), B.Tech (Mech), M.E. Strut (Hons),M.Sc (REV) (P&M),M.B.A.,M.I.E.,
F.I.V., F.I.C.C., F.A.C.C.E.,M.I.C.A., P.G.D in QS and Valn, P.G.D in Strut (Hons)
C.Engg., P.Engg.,& L.L.B Principal Consultant.

- ✦ Chartered Surveyor, Chartered Engineer ,
Govt. Approved Valuer, Professional Engineer and
Arbitrator
- ✦ Structural Consultant, Civil & Mechanical Engineer
- ✦ Regd. Valuer for Income Tax , Wealth Tax &
Gift Tax.
- ✦ Collector's Panel Engineer - Class - 1A
for Coimbatore, Tirupur & The Nilgiris Districts
Tamil Nadu Public Building (Licensing) Act-
1965, Govt. of Tamil Nadu.
- ✦ Approved competent Person Office of the
Industrial Safety and Health, Tamil Nadu.
- ✦ Panel Valuer for Banks :-
Immovable properties, plant & machineries.



ENGINEERS & VALUERS

Dr. M.V.MOHANAKRISHNAN Ph.D., MRICS (LONDON),
B.E. (Civil), B.Tech (Mech), M.E. Struct (Hons), M.Sc. (REV), M.Sc. (P&M), M.B.A., M.I.E., F.I.V., F.I.C.C.,
F.A.C.C.E., M.I.C.A., P.G.D. in Q.S. Valn., P.G.D. in Struct (Hons), C.Engg., P.Engg., & L.L.B
PRINCIPAL CONSULTANT

- ★ Chartered Surveyor, Chartered Engineer,
Govt. Approved Valuer, Professional Engineer & Arbitrator
- ★ Structural Consultant, Civil & Mechanical Engineer
- ★ Regd. Valuer for Income Tax, Wealth Tax & Gift Tax
- ★ Collector's Panel Engineer - CLASS-1A,
for Coimbatore, Tirupur & The Nilgiris Districts
Tamil Nadu Public Building Act - 1965
- ★ Competent Person : Industrial Safety and Health, Tamil Nadu.
- ★ Panel Valuer for Banks :
Immovable Properties, Plant & Machineries



Falcon Associates Engineers & Valuers

An ISO 9001:2015 Certified Engg. Concern

Kamalakrishna Towers,
386/11, 2nd Floor, Kamarajar Road,
Lakshmiapuram, Ramanuja Nagar Bus Stop,
Peelamedu, Coimbatore - 641 004.

Ph : 0422 2573259, 0422 49781221

Cell : 98431 28257, 94437 28257

E-mail : falconpoy2003@gmail.com

No. : 10285

POY2106006

DECLARATION

I **M.V.Mohanakrishnan** office at Falcon Associates, Kamalakrishna Towers,
386/11, 2nd Floor, Kamarajar Road, Lakshmiapuram, Ramanujam Nagar Bus Stop, Peelamedu,
Coimbatore - 641 015. Do hereby declare that I possess the qualification and experience specified
in the Table to rule 11 of the Madras Public Building (Licensing) Rules 1966 for issuing the
certificate of Structural Soundness of the Building covered by the certificate.

Station : Coimbatore

Date : 14.06.2021

Signature of the certifying Engineer
Registration No: 02 / 2016, Class : 1A

M. V. Mohanakrishnan
14.06.2021

Dr. M.V. MOHANAKRISHNAN Ph.D., MRICS (London)
B.E. (Civil) B.Tech (Mech), M.E. Struct (Hons), M.Sc. (Valn.), M.B.A.,
M.I.E., F.I.V., F.I.C.C., P.G.D. In Q.S. Valn., P.G.D. In Struct (Hons), & L.L.B.,
Regd. No : 02/2016, Class Class 1A

FALCON ASSOCIATES
COIMBATORE DISTRICT
COLLECTOR'S PANEL ENGINEER
PWD APPROVED ENGINEER
GOVERNMENT OF TAMILNADU
CELL : 98431 28257



1. Name and Address of the Collectors
Panel Engineer

..... **Dr. M.V Mohanakrishnan,**
Kamalakrishna Towers, 386/11,
2nd Floor, Kamarajar Road, Lakshmipuram,
Ramanujam Nagar Bus Stop
Peelamedu, Coimbatore - 641 015
Phone : 0422 - 2573259.

2. Engineering Qualification

..... Ph.D., MRICS [London] B.E, (Civil), B.Tech (Mech),
M.E. Strut (Hons)., M.Sc(REV).,M.B.A.,M.I.E., F.I.V.
F.I.C.C., F.A.C.C.E., M.I.C.A., P.G.D in Q.S and Valn,
P.G.D in Strut (Hons)., C.Engg , P.Engg & L.L.B.,

3. P.W.D Panel Engineer Appd. No

..... Board of Eng. Proceeding No:
AEE/T1/AE/21807/2016
P.W.D - Chepauk - Chennai,
Govt. of Tamil Nadu.

4. Collector Panel Engineer
Appd. No

CLASS - 1A
..... Coimbatore District's - Panel of Registered
Engineer Ref : 22934/2015/ C2,
Dated on : 15.07.2016

5. Number of years of experience
and nature thereof

..... A total of 26 Years experience in
Construction field (Designing and
Execution of Multistoried framed
Structures including 5 years
Service in Foreign Countries)

Memo
14.06.2021
Dr. M.V. MOHANAKRISHNAN Ph.D.,MRICS(London)
B.E.,(Civil) B.Tech (Mech), M.E.Struct (Hons),M.Sc.(Valn),M.B.A.,
M.I.E.,F.I.V.,F.I.C.C., PGD in Q.S. Valn.,PGD in Struct (Hons),&LLB,
Regd. No : 02/2016. Class Class 1A

FALCON ASSOCIATES
COIMBATORE DISTRICT
COLLECTOR'S PANEL ENGINEER
PWD APPROVED ENGINEER
GOVERNMENT OF TAMILNADU
CELL : 98431 28257



STATEMENT ACCOMPANYING FORM A

1. Name of the Applicant : "MICHAEL JOB MATRICULATION
HIGHER SECONDARY SCHOOL"
2. Location (Street No: Ward No. : S.F.No:692/1A2B1, 692/1A2B2, 692/1A2B3,
Name of place i.e. 693/1, 693/3, Komba Thottam, Ravathur,
Corporation, Municipality, MGP Road, Irugur Village,
Panchayat Union / Township / Sulur Taluk,
Cantonment Coimbatore District.
3. Year of construction : 2002
4. Approximate cost of construction as per
Current rate : Rs.170.00 Lakhs
5. Purpose for which the building is
being used or proposed to be used : School Purpose
6. Purpose for which the Building has Hither
to Been Used : School purpose
7. Details of construction of the building
particulars of foundation soil,
specification of the various parts under

R.C.C. Framed Building

- a) Foundation : P.C.C. 1:4:8 Mix for foundation Concrete
R.C.C. for Column footing.
- b) Basement : Brick work with CM over R.C.C. Plinth
beam
- c) Super structure : Framed Structure – R.C.C for Columns &
Beams. All round wall is constructed in B.W.
Masonry with C.M. Finished with plastering with
CM & two coats of White cement.
- d) Floor and roof : Mosaic Tiles Flooring & R.C.C Roof Slab
- f) No. of storeys. : Ground + 3 Floors only



Dr. M.V. MOHANAKRISHNAN Ph.D, MRICS(London)
B.E.(Civil) - B.Tech (Mech), M.E.Struct (Hons), M.Sc.(Valn), M.B.A.,
M.I.E., F.I.V., F.I.C.C., PGD In Q.S. Valn., PG.D In Struct (Hons), & L.L.B.,
Regd. No : 02/2016. Class Class 1A

FALCON ASSOCIATES
COIMBATORE DISTRICT
COLLECTOR'S PANEL ENGINEER
PWD APPROVED ENGINEER
GOVERNMENT OF TAMILNADU
CELL : 98431 28257


8. Period for which licence required : 3 years from 15.06.2021 to 14.06.2024
9. No. of. Persons to be accommodated : 960 Nos

BUILD-UP AREA DETAILS :-

R.C.C ROOF FRAMED STRUCTURE:-

AREA OF THE EXI GROUND FLOOR R.C.C ROOF BUILDING	=	6687.25 SFT
AREA OF THE EXI FIRST FLOOR R.C.C ROOF BUILDING	=	6687.25 SFT
AREA OF THE EXI SECOND FLOOR R.C.C ROOF BUILDING	=	6687.25 SFT
AREA OF THE EXI THIRD FLOOR R.C.C ROOF BUILDING	=	6687.25 SFT
TOTAL BUILDUP AREA	=	26749.00 SFT

Special Note : The 3rd Floor building is kept under lock and it is presently use for storage purpose only


14-06-2021
SIGNATURE OF THE OWNER
OF THE BUILDING
Date:


14.06.2021
SIGNATURE OF THE ENGINEER
Date: 14.06.2021



Dr. M.V. MOHANAKRISHNAN Ph.D.,MRICS(London)
B.E.,(Civil) B.Tech (Mech), M.E.Struct (Hons),M.Sc.(Valn),M.B.A.,
M.I.E.,F.I.V.,F.I.C.C., PG.D in C.S. Valn.,PG.D In Struct (Hons),&LLB,
Regd. No : 02/2016. Class Class 1A

FALCON ASSOCIATES
COIMBATORE DISTRICT
COLLECTOR'S PANEL ENGINEER
PWD APPROVED ENGINEER
GOVERNMENT OF TAMILNADU
CELL : 98431 28257

Certified that no addition or alteration has been made to the existing building or portion of a building for which this application has been made. I undertake to obtain a fresh license in case any alteration is made to the existing building or portion of building. I also undertake to obtain a fresh license if the purpose for which the license was granted for the use of the building or a portion of the building originally is changed or altered subsequently.

Date: 14-06-2021




SIGNATURE OF THE OWNER
OF THE BUILDING

FORM NO. 'B'

(FORM OF CERTIFICATE OF STRUCTURAL SOUNDNESS UNDER SUB SECTION (4) OF SECTION 4 OF THE TAMIL NADU PUBLIC BUILDINGS (LICENSING) ACT 1965, (TAMILNADU ACT 13 OF 1965) REFERRED TO IN RULE 4 OF THE TAMILNADU PUBLIC BUILDINGS (LICENSING) RULES 1966)

I certify that I have inspected the building mentioned in the statement and furnished below its salient features.

1. FOUNDATION:

- (I) Depth below ground level : 8'0" for Column
- (ii) Nature of soil met with at : Kankar with conlomeric soil
- (iii) Probable safe bearing capacity
Of the soil met with at foundation : 33.00 M.T/ M²
- (iv) Pressure at foundation : 14.80 M.T/M²

2. SUPER STRUCTURE:

- (i) Maximum stress in the most
Critical section of masonry
and concrete : R.C.C 1 : 2 : 4 50.00 Kg / Cm²
B.W in C.M 12.50 M.T / Sft.
- (ii) Nature of masonry and concrete
and its safe permissible stress : R.C.C 1 : 2 : 4 100.00 Kg / Cm²
B.W in C.M 35.00 M.T / Sft.

The structural soundness of the building has been verified by me with reference to I.S.I. Loading standards 875 (Latest version) and other relevant Indian standard code of practice and I declare that the building is structurally sound to be used as a public building for the purpose noted in the statement. A license may be granted for the period from [3 years] 15.06.2021 to 14.06.2024

M. V. Mohanakrishnan
14.06.2021

SIGNATURE OF THE ENGINEER

Date: 14.06.2021

Address:

Dr. M.V. MOHANAKRISHNAN Ph.D., MRICS(London)
B.E.(Civil) B.Tech (Mech), M.E.Struct (Hons), M.Sc.(Valn), M.B.A.,
M.I.L., F.I.V., F.I.C.C., PG.D. in C.S. Valn., PG.D in Struct (Hons), & LL.B.,
Regd. No : 02/2016, Class Class 1A



FALCON ASSOCIATES
COIMBATORE DISTRICT
COLLECTOR'S PANEL ENGINEER
PWD APPROVED ENGINEER
GOVERNMENT OF TAMILNADU
CELL : 98431 28257

STATEMENT ACCOMPANYING
THE CERTIFICATE OF STRUCTURAL SOUNDNESS

1. Location of the building Door
Number, Street and Name of the place : **"MICHAEL JOB MATRICULATION
HIGHER SECONDARY SCHOOL"**
S.F.No:692/1A2B1, 692/1A2B2, 692/1A2B3,
693/1, 693/3 Komba Thottam, Ravathur,
MGP Road, Irugur Village,
Sulur Taluk,
Coimbatore District - 641109
2. The Value of the building
at the Current rates : Rs.170.00 Lakhs
3. Age of the building : 19 Years
4. Number of Storeys : Ground +3 Floor only
5. Short description of structures – Steel – : R.C.C Roof Framed Structure G.F, F.F, S.F &
T.F Brick work with C.M Plastered ply
wood, Steel Doors, Gil with Glassed
Windows, Ventilator Mosaic & Tiles
Flooring – Etc...
6. Purpose for which the building is
Certified for use : School Purpose
7. The period for which the building will be
Structurally sound : 3 Years 15.06.2021 to 14.06.2024
8. Number of persons to be
Accommodated : 960 Nos
9. Remarks : Regular Maintenance is required.

Date: 14.06.2021

M. Mohan
14.06.2021

SIGNATURE OF THE ENGINEER

Address:

Dr. M.V. MOHANAKRISHNAN Ph.D.,MRICS(London)
B.E.,(Civil) B.Tech (Mech), M.E.Struct (Hons),M.Sc.(Valn),M.B.A.,
M.I.E.,F.I.V.,F.I.C.C., PG.D in C.S. Valn.PG.D in Struct (Hons),&LLB.,
Regd. No : 02/2016, Class Class 1A



FALCON ASSOCIATES
COIMBATORE DISTRICT
COLLECTOR'S PANEL ENGINEER
PWD APPROVED ENGINEER
GOVERNMENT OF TAMILNADU
CELL : 98431 28257

FORM - C

Form of certificate of Structural Soundness under sub-section (4) of section 4 of the Madras Public Buildings (Licensing) Act 1965 (Madras Act 13 of 1965) referred to in rule 4 of the Madras Public Buildings (Licensing) Rules 1966.

I certify that I have inspected the building mentioned in the statement below and I have satisfied myself that the building is structurally sound to be used as a public building for the purpose noted in the statement. The structural soundness of the building has been verified taking into account the Loading as per the latest Indian standards 875. A license may be granted for three years period from 15.06.2021 to 14.06.2024 Three years (inclusive).

M. V. Mohan
14.06.2021

SIGNATURE OF THE ENGINEER

Address:

Dr. M.V. MOHANAKRISHNAN Ph.D., MRICS(London)
B.E.,(Civil) B.Tech (Mech), M.E.Struct (Hons), M.Sc.(Valn), M.B.A.,
M.I.E., F.I.V., F.I.C.C., PG.D in Q.S. Valn., PG.D in Struct (Hons), & LL.B.,
Regd. No : 02/2016, Class Class 1A



FALCON ASSOCIATES
COIMBATORE DISTRICT
COLLECTOR'S PANEL ENGINEER
PWD APPROVED ENGINEER
GOVERNMENT OF TAMILNADU
CELL : 98431 28257



Date: 14.06.2021

ACCOMPANY THE CERTIFICATE OF STRUCTURAL SOUNDNESS:

Location of the Building (Door No., Street, name of the place)	Age of the Building (Year)	Approximate Cost of construction as per current rate	Number of Storeys	Short description of structures – Steel – RCC framed or load Bearing masonry	Purpose for which the building is Certified for use	The period for the period for building will be structurally sound	Number of persons to be Accommodated Nos.	Remarks
1 "MICHAEL JOB MATRICULATION HIGHER SECONDARY SCHOOL" S.F.No:692/1A2B1, 692/1A2B2, 692/1A2B3, 693/1, 693/3, Komba Thottam, Ravathur, MGP Road, Irugur Village, Sular Taluk, Coimbatore District - 641109	2 19 Years	3 Rs.170.00 Lakhs	4 G.F, F,F, S.F & T.F only	5 Framed Structure Building	6 School Building	7 3 Years. From <u>15.06.2021</u> to <u>14.06.2024</u>	8 960 Nos	9 Regular Maintenance is Required

Date: 14.06.2021



SIGNATURE OF THE ENGINEER

Address:
Dr. M.V. MOHANAKRISHNAN Ph.D, MRICS(London)
B.E./Civil Engg. (Mech), M.E.Struct (Hons), M.Sc.(Valn), M.B.A.,
M.L.S., F.I.C.C. PGD in C.S Valn., PGD in Struct (Hons), & LL.B,
Regd. No . 02/2016, Class Class 1A

FALCON ASSOCIATES
COIMBATORE DISTRICT
COLLECTOR'S PANEL ENGINEER
PWD APPROVED ENGINEER
GOVERNMENT OF TAMILNADU
CELL : 98431 28257

Memorandum
14.06.2021

FORM - E


Form of Report to be made to the competent Authority by Inspecting Authorities or Officers Under Section 238 of the Madras Public Building(Licensing Act 1965 Madras act 13 of referred to in rule 7 of the Madras Public Building (License) Rule 1966

1. Name and designation of Inspecting authority or Officer appointed of having Justification Under other act of law : **Dr.M.V.Mohanakrishnan.**
2. Location of the Building : **S.F.No:692/1A2B1, 692/1A2B2, 692/1A2B3, 693/1, 693/3, Komba Thottam, Ravathur, MGP Road, Irugur Village, Sular Taluk, Coimbatore District - 641109.**
- Inspected (Door No.st. Name of the Place i.e. Municipal Corporation /Municipality Union /Township/Cantonment
3. Date of Inspection : **14.06.2021**
4. Purpose for which the Building is used : **School Purpose**
5. Nature of defects Noticed : **Minor Cracks in Walls.**
6. Suggestion for rectifying Defects : **Chemical filling & Painting**
7. If in a dangerous condition : **Periodically Maintenance should be done.**
- Immediate steps recommended To be taken

Conditions for the Existing Structures:

1. This building was inspected on 14.06.2021 along with the School Staff (Cell: 86100-83010) for structural soundness verification.
2. If any cracks etc., developed in the Structure in the said period for which Stability Certificate issued, should be brought to the notice of the undersigned Panel Engineer.
3. The Structural Soundness Certificate shall be revoked if any defects are notice during the said period.
4. The Panel Engineer reserves the right to inspect the Building at any working hours and if any defects found during his visit then this Structural Soundness Certificate may be revoked without assigning any reasons.
5. No addition or alteration should be made to the existing Structure or portion of the Building without the prior written permission from the Panel Engineer empanelled by the District Collector of the particular District.
6. If any alterations or additions made to the existing Building covered in this Structural Soundness Certificates, a fresh Soundness Certificate should be obtained from the Panel Engineer of the particular District under the relevant Class.
7. Any other activities other than School without the Knowledge of the undersigned will not bind this stability certificate.
8. Legal aspects are not considered in this stability certificate.
9. The proper maintenance of the site and building to be given to keep the structural stability in a good manner. Further it is informed that any defects or collapse if any.
10. Due to any removal of any part of the building the undersigned is not responsible for the some. Caused due to Natural Calamities like Earthquake, Cyclones, Floods, Heavy Rain etc., are not considered in the stability of building.
11. Special Precaution should be follow in all Under Construction building areas with in the site boundary.
12. This certificate being issued only for the stability and Soundness of the building for the duration of period mentioned in this report.
13. Report contains 12 Pages.

Signature of the Owner of the Building
Date:


14-06-2021




(4.06.2021)
SIGNATURE OF THE ENGINEER
Dr. M.V. MOHANAKRISHNAN Ph.D., MRICS(London)
B.E., (Civil), B.Tech. (Mech), M.E.Struct (Hons), M.Sc.(Valn), M.B.A.,
M.I.E., F.I.V., F.I.C.C., P.G.D. in Q.S. Valn., P.G.D. in Struct (Hons), & LL.B.,
Regd. No : 02/2016, Class Class 1A

FALCON ASSOCIATES
COIMBATORE DISTRICT
COLLECTOR'S PANEL ENGINEER
PWD APPROVED ENGINEER
GOVERNMENT OF TAMILNADU
CELL : 98431 28257

Proceedings of the District Collector, Coimbatore.

Present : Thiru.T.N.Hariharan, I.A.S.,

Ref.No.22934/2015/C2

Dated: 15.07.2016.

Sub : Tamil Nadu Public Building Licensing Act 1965 -
Upgradation of the name of Thiru.M.V.Mohanakrishnan in
the panel of private practicing engineers from CLASS-I to
CLASS-IA category in Coimbatore district - Approval of the
board of engineers - orders issued -reg

Ref : 1. Superintending Engineer, PWD Buildings(C&M)Circle,
Coimbatore Lr.No.DB/DO.2/F.1142/22M/2015
dated.12.01.2016.
2. Engineer-In-Chief, WRD, and Chief Engineer(General),
PWD, Chennai Lr.No.AEE/T1/AE/21807/2016
dated.22.06.2016

ORDER-

The Engineer-In-Chief, WRD, and Chief Engineer(General), PWD, Chennai in the reference 2nd cited has stated that the board of engineers in its 516th Board of Engineering Meeting has resolved and approved the name of Thiru.M.V.Mohanakrishnan (D.O.B-15.03.1967) for inclusion and registering in the panel of Private Practicing Engineer for the Upgradation from Class I to Class-IA category (Buildings, the cost of which exceeds Rs.50 lakhs as per G.O.Ms.No.43, Municipal Administration & Water Supply (MA4) Department, dated.17.02.2011) in Coimbatore District.

Accordingly, Thiru.M.V.Mohanakrishnan has been included in the panel of Private Practicing Engineers for the Upgradation from Class-I to Class-IA category (Buildings, the cost of which exceeds Rs.50 lakhs as per G.O.Ms.No.43, Municipal Administration & Water Supply (MA4) Department, dated.17.02.2011) in Coimbatore district and entered the name against Sl.no.02/2016 in the register of panel of Private Practicing Engineer in Category -IA maintained in this office.

Sd/-T.N.Hariharan
District Collector,
Coimbatore.

To


✓Thiru.M.V.Mohanakrishnan
Falcon Associates, 216-Durai's Complex,
1st Floor, Rajamill Road,
Pollachi-642001



Copy to

1.Superintending Engineer, PWD Buildings(C&M), Coimbatore
2.Enginer-In-Chief, WRD, and Chief Engineer(General), PWD, Chennai

//By Order//


15.7.16
For District Collector


15/7/16