

District Level Water Testing Laboratory, Dhanbad
 Drinking Water & Sanitation Department
 Dhanbad, 826001 Jharkhand

Serial No. 311/19 Date 18/10/19
 Location - DELHI PUBLIC SCHOOL
KARMIK NAGAR, DHANBAD

Collected Sample source - R.O
 Name - School

Water Quality Report

Parameter	Iron	Nitrate	Fluoride	Chloride	TDS	PH	Alkalinity	Hardness	Arsenic	Turbidity	Bactari a
Acceptable limit	0.3mg/l	45mg/l	1.0mg/l	250mg/l	500mg/l	6.5mg/l	200mg/l	200mg/l	0.01mg/l	1NTU	Level
Permissible limit (in the absence of alternate source)	1.0mg/l	45mg/l	1.5mg/l	1000mg/l	2000mg/l	8.5mg/l	600mg/l	600mg/l	0.05mg/l	5NTU	Level
Result	0.17	-	-	-	36	7.2	20	30	-	0.1	-

(Safe.....)
 (Unsafe.....)



S. K. ...
 Lab Analyst
 D.L.W.T.L. Dhanbad

S. K. ...
 Technical Manager
 D.L.W.T.L. Dhanbad