

# Annexure C

## PROFORMA FOR SAFE DRINKING WATER AND SANITARY CONDITION CERTIFICATE

No. 195

Dated: 18/5/24 (Myself)

It is certified that an inspection team headed by Saurabh Kr. Singh Asstt. Engineer

(Name of Officers with designation) from Biharsharif.....PHED

inspected the Indian Wisdom School, Telmar Road Narsanda char

(Name & Address of the school) on 17.05.2024.....(date of inspection) and on the basis of

Water Test Report (Attached) bearing no. 98/2024..... dated 18.05.2024

of DWTL Biharsharif (PHED Lab) certified that the


Indian Wisdom School.....( Name of school) has safe drinking water

facilities for the students and members of staff of the institution. School is also maintains the

hygienic sanitation condition in the school building & the campus as per norms prescribed by the

Central/ State/ U.T. Govt.

This certificate is valid till for present conditions only

Signature with Seal:   
Name: S. A. R. ABHA KR. SINGH  
Designation: ASSISTANT ENGR.  
Name & Address of the Office / Department : .....


P. H. SUBDIVISION  
अवर प्रमण्डल पदाधिकारी  
लोक स्वा० अवर प्रमण्डल  
बिहार शरीफ (नालन्दा)

To Indian Wisdom School

(Name & Address of the Institution)

Note: The certificate is to be issued by authorized officer / PHED Lab / local bodies

Nishant Kumar  
MANAGER  
INDIAN WISDOM SCHOOL  
(NALANDA)

  
PRINCIPAL  
INDIAN WISDOM SCHOOL  
(NALANDA)

Government of Bihar  
Public Health Engineering Department  
Water Quality Report

No. 98/2024.

Date: - 18.05.2024

District Name: Nalanda		Date of Sampling :- 17/05/2024										Source of Water									
Sample Collected by :- Prawesh Malik		Name of Habitation		Village		Location of Source		Test result													
Sl. No.	Block	Panchayat	Village	Name of Habitation	Location of Source	pH	Turb.	EC	TDS	TH	Ca	Mg	Ci	Alka.	Fe	NO <sub>3</sub>	SO <sub>4</sub>	F	As	Source of Water	
1	2	3	4	5	7	8	9	10	11	12	13	14	15	16	17	18	19	20	21	23	
1	Chandi	Narsanda	Telmar Road Narsanda	Telmar Road Narsanda	Indian Wisdom School Telmar Road Narsanda	7.10	0.754	415	225	116	40	22	35	128.5	0.11	0.13	4.1	0.35	-	Tube Well	
Desirable Limit*						6.5-8.5	1.0	-	500	300	75	30	250	200	1.0	45	200	1.0	0.01	-	
Permissible Limit* in absence of alternate source						NR	5.0	-	2000	600	200	100	1000	600	NR	NR	400	1.5	0.05	-	

*Prajapati*  
18/05/24

Public Health Division, Bihar Sharif  
(Nalanda)

Public Health Division  
Bihar Sharif (Nalanda)

*Nishant Kumar*

MANAGER  
INDIAN WISDOM SCHOOL  
(NALANDA)

*[Signature]*  
PRINCIPAL  
INDIAN WISDOM SCHOOL  
(NALANDA)